



Fire Marshal's Office

City of Pearland

2703 Veteran's Drive

Pearland, Texas 77584

Phone: 281.997.4650 | Fax: 281.997.4660

pearlandtx.gov

Fire Alarm Plan Review Checklist

- _____ Permit application includes valuation of work
- _____ Copy of License submitted with plans
- _____ Copy of Insurance (in the name of the City of Pearland) submitted with plans
- _____ Plans, cut sheets, and battery calculations need to be submitted in PDF format
- _____ Duct detectors must have remote indicators and are capable of being reset at ground level
- _____ Duct detectors trigger a general alarm, not a supervisory
- _____ Weather proof horn/strobe tied to the water flow switch and placed outside the riser room
- _____ Tamper on the PIV and the riser
- _____ Alarm initiating devices are addressable at panel and monitoring.
- _____ Monitoring matches the addressable FACP
- _____ Remote annunciator is alpha numeric
- _____ Alarm notification is ADA compliant and synchronized
- _____ Complete coverage where applicable
- _____ Smoke detector above FACP
- _____ System complies with Current applicable addition of NFPA 72
- _____ Document box must be location at main FACP