



PEARLAND FIRE DEPARTMENT

2703 Veterans Dr. Pearland, Texas 77581 281.997.5851

One City, One Mission, One Fire Department



Fire Marshal's Office

Fire Department Connection (FDC) Sign Design Requirements

1. Signs shall be constructed from an 18" high by 24" wide metal substrate no thinner than .063.
2. Background color of sign shall be "Fire Engine Red" non-reflective.
3. White reflective letters shall be used as set out below.
4. Sign shall be permanently attached to the Fire Department Connection.
5. First line (FDC) shall be 6" high letters with 3" spacing between letters.
6. Second and third lines shall be at least 4" high letters and ½" spacing between letters.
7. There shall be a 1" margin completely around sign and 1" spacing between lines of text.
8. There shall be 2" spacing between any complete words.



Example